

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 12:08 pm

**PWS ID:** UTAH13037      **Name:** NEW PARIA SUBDIVISION  
**Legal Contact:** NEW PARIA SUBDIVISION      **Rating:** Approved  
FRANCES THOMAS      **Rating Date:** 11/21/2002  
**Address:** PO BOX 410316      **Activity Status:** Active  
BIG WATER, UT 84741  
**Phone Number:** 435-645-3259  
**City Served (Area):**  
**County:** KANE COUNTY  
**System Type:** Community      **Last Inv Update:** 03/11/2009      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 04/03/2008      **Total Dsgn Cap:**  
**Population:** 35      **Surveyor:** CHAD REEDER      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

Gal/Day Gal/Min

### Contacts

Contact Type	Name	Title	Phone Numbers Office	Emergency	Email Address
AC	THOMAS, FRANCES		435-645-3259		

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unmetered	0	19
Commercial	Unmetered	0	2
			21 Total Svc Connections

### Storage

**Total Storage:** 50,000 GAL      **Number of Units:** 3      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST003	2007 CONCRETE STORAGE TANK	Ground	50,000 GAL	Concrete	4519	A	NO
ST001	STORAGE FACILITY ST001 ABANDC	Ground	0 GAL	Steel		I	
ST002	STORAGE FACILITY ST002 ABANDC	Ground	10,000 GAL	Steel		I	

### Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	NEW PARIA OLD WELL	Inactive	WL	8			Yes	GW	Other		
WS002	NAVAJO GEOLOGY WELL	Active	WL			72 GPM	Yes	GW	Permanent	1/1 to 12/31	

\*Reports measured flow for wells, approved design capacity for all other sources.